Standpipe Fire Hose Inspection Log

School: _____ **Year:** _____

❑ Inspect water control valves – should be closed and tight	❑ Test cabinet door – open and close/latch
❑ Inspect hose connection to valve – hand tighten only	❑ Inspect Service Agency Label
❑ Test Discharge Nozzle – open & close, then leave closed	❑ Record all deficiencies

LOCATION	LENGTH	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec